



Letter of Attestation

Document: 2011806

Master Contract: 242437

Project: 2775145

Date Issued: April 10, 2015

Issued to: Pietro Fiorentini S.p.A.
Via Enrico Fermi 8/10
Arcugnano, Vicenza 36057
Italy
Attention: Armando Amadini

CSA Group, Certification and Testing hereby confirms that it has completed an evaluation of
Models: See Appendix A – Attached
Commercial Name: GOVAL

*CSA Group, Certification and Testing hereby attests that the products identified above and described
in test report 2775145 dated October 14, 2014
complies with the following standards/tests, to the extent applicable:*

ANSI Z21.80/CGA-6.22-2011
With Inlet Pressure of 15 PSI (1 bar)*

Issued by: 
Richard Clark
Certification Engineer

* 15 PSI (1 bar) inlet pressure is outside of the scope of the above standard. However; the above standard and test methods were adapted where possible to validate acceptable performance.

THIS LETTER OF ATTESTATION DOES NOT AUTHORIZE THE USE OF THE CSA MARK ON THE SUBJECT PRODUCTS.

QUOTATIONS FROM THE TEST REPORT OR THE USE OF THE NAME OF THE CANADIAN STANDARDS ASSOCIATION AND CSA GROUP OR ITS REGISTERED TRADEMARK, IN ANY WAY, IS NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT OF THE CANADIAN STANDARDS ASSOCIATION OPERATING AS CSA GROUP, CERTIFICATION AND TESTING DIVISION.



Document: Appendix A
Project: 2775145

Master Contract: 242437
Date: April 10, 2015

Governor/Regulator: GOVAL

WITHOUT FILTER VERSION

| Model Number | Size | Maximum inlet Pressure PSIG | Flow Capacity SCFH at 1 PSI Inlet & 7" WC |
|--------------|-------|-----------------------------|---|
| 30061 | 1/2 | 15 | 462 |
| 30062 | 3/4 | 15 | 581 |
| 30063 | 1 | 15 | 746 |
| 30160 | 1/2 | 15 | 1120 |
| 30161 | 3/4 | 15 | 1411 |
| 30162 | 1 | 15 | 1659 |
| 30163 | 1 1/4 | 15 | 4522 |
| 30164 | 1 1/2 | 15 | 4729 |
| 30165 | 2 | 15 | 9959 |
| 30166/F | 2 1/2 | 15 | 12282 |
| 30167/F | 3 | 15 | 14935 |
| 30168/F | 4 | 15 | 26135 |

WITH FILTER VERSION

| Model Number | Size | Maximum inlet Pressure PSIG | Flow Capacity SCFH at 1 PSI Inlet & 7" WC |
|--------------|-------|-----------------------------|---|
| 31061 | 1/2 | 15 | 462 |
| 31062 | 3/4 | 15 | 581 |
| 31063 | 1 | 15 | 746 |
| 31160 | 1/2 | 15 | 992 |
| 31161 | 3/4 | 15 | 1280 |
| 31162 | 1 | 15 | 1490 |
| 31163 | 1 1/4 | 15 | 3640 |
| 31164 | 1 1/2 | 15 | 4550 |
| 31165 | 2 | 15 | 9100 |
| 31166/F | 2 1/2 | 15 | 11420 |
| 31167/F | 3 | 15 | 12410 |
| 31168/F | 4 | 15 | 22340 |